

This paper discusses the energy savings potential of a plastic products manufacturing facility in Central Florida. The authors performed an energy audit of the facility as part of a contract with the U.S. Department of Energy to perform industrial energy assessments through DOE's Energy Analysis Diagnostic Center program. In addition to a survey of the traditional energy-using equipment such as motors and lighting, the audit team looked at energy used in the process and recommended ten energy savings measures which could save the company slightly over ten percent on its electric energy bills.

The facility manufactures a molded plastic product which is distributed nationwide. The company has about 100 employees and an annual sales figure of about \$10 million.

The facility has one building with a total area of approximately 100,000 square feet. The building has approximately 10-foot ceilings and has a corrugated steel roof. The ceiling has 1 to 2 inches of insulation.

The offices are air conditioned in sections by nine rooftop units. The main production floor is cooled by seven high efficiency rooftop air conditioning units. It is air conditioned to maintain low humidity for high product quality. The lining room uses a separate high efficiency unit located behind the building. The warehouse is not air conditioned.

The production floor of the facility operates 20 hours a day (between 7:00 and 19:00) and 5 days a week.

The electric bills for this company for May 1990 through April 1993 were approximately \$400,000 for 100,000 kWh. This is an average cost of \$4.00 per kWh. The average monthly demand was 10,000 kWh and the average demand cost was \$40,000 per month. For Energy Management Recommendations 28s: which involved a reduction in peak demand with no improvement in energy efficiency, we used an average demand rate savings of 4.1% per kWh per month which includes taxes:

---

<sup>1</sup> We would like to acknowledge the work of two other people in preparing this paper. Brent Crawford was the team leader who conducted the audit and prepared the audit report. Sumit Ray helped with the DOE analysis.

We used the average electricity cost to perform the economic analysis of all E 2 8s that involved improved energy efficiency except for equipment that is operated off-peak. In that case we used an electricity cost of \$0.0567 and did not consider the demand cost.

This company's major manufacturing operation is injection molding. The facility has twenty injection molding machines to mold and form the final product. Some of the molding machines are variable volume hydraulic while the majority are fixed volume. Cooling tower water is used to cool the circulating oil and chilled water is used to cool the hydraulics.

Plastic pellets arrive by railcar and are vacuum conveyed to separate silos located outside the building. The pellets are fed automatically from the silos into each molding machine using vacuum suction. The finished products are then packed in totes and put in the warehouse.

The company has two secondary processes. Some products require a compressed air process for finishing. Others are placed on a conveyor belt and printed with an inking machine. UV lamps dry the ink instantly.

Table # summarizes the energy management recommendations made by the E!DC audit team. If the company implements the recommended measures it will realize an annual savings on its energy bills of approximately \$4,567 for a cost savings of nearly \$11,000. The total implementation cost for these measures which is reduced by applicable utility rebates would be about \$3,000 and the simple payback period is about eleven months.

The total savings shown in Table # is not the sum of all the measures shown. E 2 8s 4 and 1 are mutually exclusive measures and we recommended only E 2 8 4. Implementation of E 2 8 1 is uncertain so it is not included in the totals either. In addition some of the measures are interrelated. For example if you replace the motor for the chilled water pump with a high efficiency motor then the savings realized from installing an adjustable speed drive on the pump will be somewhat less than shown.

We recommended five process energy management measures which save a total of \$13,000, \$5,670/yr and reduce demand by 356 kW. The energy cost savings is \$3,110. The local utility offers incentives for installing high efficiency chillers and motors. The cost to implement these five process improvements including the utility rebate is approximately \$3,000 for a simple payback period of eleven months.

1. Replace chiller	1*1*0	1)4**	1.)	1./k)**	0/4
0. Insulate molders (arrels)	/k.44	0k)0*	*)	.3k.,)	*
3. VSD for water pump	3k,41	4k1**	1.)	4.k0.4	*
/. High efficiency motors	1k, /1	.k01.	1.*	131k/11	1..3
). Reduce peak usage	3k0/.	*	#mediate	*	/*1
4. High efficiency lighting	1k0/4	0k33,	*.3	10/k,11	/4.1
1. T. lighting BB	3k/13	1/k*,1	/1	).k.),	1).3
.. Reflectors	/k/*4	4k13*	1.)	41k11*	..0
.. High efficiency VCB	1k*34	1k*0)	1.*	11k.4/	0./
1*. VCB controls	.*3	,/)	1.0	11k.0/	*
11. E-tending VCB ducts	.k1**	)k***	1.1	1)*k***	*
10. 2 miscellaneous measures	0k1),	0k401	1.1	)1k4.,	*
Totals	+) /k430	+) *k133	*,.	..4k0,.	13.

B Implementation cost is reduced (y amount of utility rate).

BB This E 2 8 is shown for information purposes only. #s values are not included in the totals at the bottom of the table.

This facility has three identical 4-ton reciprocating chillers that are at least six years old and that have a full load operating efficiency of 1.1. A computer schedules the chillers weekly so that during a given week one chiller operates all of the time, one chiller operates under varying loads about half of the time, and the third chiller is turned off. Under this system, each chiller operates 3100 hours per year.

We analyzed six alternatives for chiller replacement at this facility. We looked at three different types of new chillers: a standard efficiency reciprocating chiller, a high efficiency reciprocating chiller, and a screw chiller; and analyzed the savings for two different scenarios. For the first, we assumed that the facility would not replace a chiller until one of the existing chillers failed. For the second, we assumed that the facility would replace one of the existing chillers immediately. The

energy and cost savings, the implementation cost and simple payback period and the demand reduction for each alternative are shown in Table #. Based on our analysis, we recommended that the company should immediately replace one of its existing chillers with a new screw-type chiller.

Replace with standard efficiency chiller						
1.	On failure (asis	3k, . *	*	#mmediate	4. k40)	,.0
0.	Cow	1k,4*	0*kk**	0.)	131k0)*	1../
Replace with new high efficiency reciprocating chiller						
3.	On failure (asis	/k.)*	0k***	*/	.3k40)	10.)
/.	Cow	,k1**	00k***	0.3	141k0)*	00.3
Replace with new screw chiller						
).	On failure (asis	)k3)1	*	#mmediate	,0k0)*	10.3
4.	Cow	1*k1*0	1)k4**	1.)	1./k)**	0/4

Injection molding machine heater (ands are used to preheat the barrel and maintain the correct operating temperature of injection molding machines. However, unless the heater (ands are insulated, they lose significant heat to the surrounding air. This heat loss creates an additional cooling load for the air conditioning system. Recent studies have shown an energy savings up to 10 percent (not including air conditioning savings) when an insulating blanket is used.<sup>9</sup>

We analyzed the use of insulation blankets for the injection molding machines at this facility and determined that the insulating blankets would be feasible for use on five of the machines. We calculated the total annual energy savings for each machine as the sum of the savings associated with reduced heat loss from the barrel surface (11k, .) 5 6 7<yr: and the savings associated with reduced air conditioning load (1, / 5 6 7<yr:). The total energy savings for insulating five machines was .3k, .) 5 6 7<yr and the energy cost savings was +/k.44<yr.

We recommended purchasing blankets with straps for easy installation and removal. The blankets cost about \$110 per 1\*\* tons of machine capacity. For five 1)\*\$ton machines, the implementation cost would be \$11,000\*. This E 2 8 has a simple payback period of 4 months, making it a highly cost-effective recommendation.

<sup>2</sup> DUpgrading Injection Molding Machines for Improved Efficiency, Center for Materials Fabrication, E&S Technology Application, vol. 4, Co. 1 & 1, , 0.

This facility uses chilled water to cool the injection molding machines. The pump that supplies this process water has a 3-horsepower motor. Installing adjustable speed drives or variable speed controls on centrifugal pump motors can be very cost effective. The conventional practice for controlling such pumps is to run the motor at full speed and control the flowrate with a valve. Under this practice, the motor consumes the same amount of energy regardless of the amount of water that is being moved. This is like controlling the speed of a car with the throttle while keeping the accelerator pushed all the way to the floor. With an adjustable speed drive, the system flowrate can be varied by controlling the speed of the motor. Energy is saved because the motor consumes significantly less power.

The power required by a centrifugal pump motor increases with the cube of its speed. For example, when a pump's speed is doubled, the power required increases by eightfold ( $2^3$ ). Similarly, cutting the speed in half decreases the power requirement by a factor of eight. Because the flow rate of a centrifugal pump is directly proportional to the speed of the pump, the power required by the motor is proportional to the cube of the flow rate. Therefore, using the motor speed to directly control the

The operating efficiency of electric motors has improved in recent years. Depending on the horsepower rating, the operating efficiency of high efficiency motors can be from 1% to 10% higher than the operating efficiencies of standard motors. We inventoried the motors at this facility and determined that it would be cost effective to replace 10 of the 40 motors with high efficiency motors as the existing motors failed. For very small motors or seldom used motors, the simple payback period is too high to make replacement cost effective.

The total energy savings for this E 2 8 is 131k/11 5 6 7<yr with an energy cost savings of +1k, /1. The implementation cost for each motor was reduced by the applicable utility rebate. The total implementation cost is +.k01.k and the overall simple payback for this E 2 8 is 1 year. Table #? shows the savings analysis for the motors by horsepower.

Horsepower	Number of motors	Motor Efficiency		Energy Savings 95 6 7<yr:	Energy Cost Savings 9+<yr:	# Implementation Cost (including rebate):	Simple Payback Period
		Standard	High				
10	4	88.3%	90.5%	1.2k	331	11/	1.1
30	3	88.4%	90.3%	1.2k	43	31	1.4
30	1	88.1%	90.31%	10k	44	10	1.1
1/2	1	88.1%	90.31%	1k	0.4	0.4	1.1
10	11	88.11%	90.31%	1.3k	4k	4k	1.1
				131k/11	1k, /1	.k01.k	1.1

We analyzed the equipment use at this facility to determine which equipment could be limited to use during off-peak hours. The major savings would be realized if the company restricted monthly testing of its emergency fire pump to off-peak hours. The fire pump has 1000hp motor with a motor efficiency of 88.3%. We assumed that during a monthly test the pump would run for 10 minutes during a peak demand window of 10 minutes. Under those conditions, the power consumption of the motor was calculated as 1.5 6. Shifting this use to off-peak times would provide an annual demand charge savings of +3k0/.<yr. Because the company operates three shifts, testing the fire pump off-peak would be feasible.

We surveyed the lighting in the facility and recommended replacement of standard efficiency lamps with high efficiency lamps. Table 2 shows the type and number of each type of lamp in the facility and shows the annual energy use and cost savings that will be realized when all of the lamps of each type have been replaced with high efficiency lamps.

141	CF/*	10,134	141	7F3/	1,31*	110*
.0	CF1)	44/*	01*)	7F4*	,30.	)/0
1,	#G1**	/,/*	0.1	C 2 F01	34*4	0*,
13	#G1)	1313	/0/	C 2 F13	4*/)	3)1
11,	2 ?/**	/1*(*)*	03.10	7 2 ?30)	.440.	)*0/
		),.11,	3/4,)		10/,11	10/4

The energy savings from high efficiency lighting also includes a savings of 00\*\* 5 6 7<yr due to the reduced heat load on the air conditioning system. Therefore the total energy savings for this E 2 8 is 101114 5 6 7<yr and the cost savings is +1313.

In most cases we recommend replacement of lamps on a failure (asis 9spot relamping: (ecause the pay(ac' period is much longer with a group relamping program. Table 2# shows the costs and pay(ac' for (oth methods (ecause the local utility will only pay a re(ate for replacement through a group relamping program.

We also analy@d replacing the CF/\* lamps with T\$. lamps. ; ecause replacement with T\$.s re%uires a new fi-ture& group relamping is the only feasi(le implementation method for this lamp. #n addition& the local utility pays a higher re(ate for relamping with T\$. lamps (ecause the change is more permanent than relamping with 7F3/ lamps. Table 2## compares the three alternatives for replacement of CF/\* lamps.

	)3/	*)	1k3)4	1.3
	.0	*.0	)*1	*.,
	1k1,*	*.3	/k133	1.1
	0.4	*..	01)	*..
	0/1	1.0	00.	1.1
	0k33,	*./	1k*,,	1.1

7F3/ 9spot:	0)k0/ .	1k/4/	4.,	)3/	*./
7F3/ 9group:BB	0)k0/ .	1k/4/	4.,	1k3)4	*.,
T. 9group:BB	) .k. ),	3k/13	1).3	1/k*,1	/.1

B #ncluding savings from reduced air conditioning load.  
BB The implementation cost is reduced (y the applica(le utility re(ate.

Choosing the appropriate alternative for CF/\* replacement involves a num(er of factors. !lthough the pay(ac' for the T.s is longerk this alternative includes new (allasts and new fi-turesk meaning that (allasts and fi-tures will not need replacing anytime soon. Other factors that must (e considered include lamplife and (allast life.

The lamp lifes of the T.s and the 7F3/s are e%ual 90.41 years for the office area and 1.4, years for the production floor. Therefore group relamping with T. lampsk with a simple pay(ac' period of /.1 years does not appear to (e cost effective in the office areas (ecause the T.s would need to (e replaced 9in 0.41 years: (efore they had paid for themselves. #n the office areask thereforek 7F3/s with a pay(ac' period of \*., years seem to (e a (etter group relamping choice. #n the production area howeverk (oth 7F3/s and T.s would last long enough 91.1 years: for their implementation costs to (e fully reali@ed.

Since T.s present significantly higher annual savings they might (e a (etter group relamping choice in the production area. 7oweverk there are 1k\*0) CF/\*s in the office area and only /0 in the production area. Thereforek we recommended replacing the CF/\* lamps with 7F3/s.



Reflectors are available for fluorescent lamp fixtures which increase the light output of the fixture. When the reflector is installed in a four-lamp fixture, two of the lamps and one of the ballasts can be disconnected without decreasing the light level significantly. In this facility, we recommended installing 0% reflectors in the office areas because the offices were overlighted. The lighting level in the offices was between 10 and 100 footcandles, the recommended level for office work is 10 footcandles.

The energy and demand savings from installing reflectors results from disconnecting lights and ballasts. This facility had a total of 1000 CF lamps and 100 ballasts. However, we calculated the energy savings using 750 lamps instead of 1000 lamps, assuming the facility would implement our recommendation to install the higher efficiency lamps. The energy savings of 41,111 kWh/yr includes a savings on reduced air conditioning load of 10,000 kWh/yr. The total cost savings of \$1,400/yr includes an energy cost savings of \$300/yr as well as an equipment cost savings of \$1,100/yr as a result of having only half as many ballasts and lamps to replace each year. Note that this is a conservative estimate because it does not include a labor cost savings on replacing equipment.

The cost of purchasing and installing the reflectors and disconnecting the lamps and ballasts was estimated at \$300 per reflector for a total cost of \$30,000. The local utility offers a rebate for installing reflectors of \$100 per fixture reduced. Because this E 28 reduces the demand by 0.56 kW, the rebate will be \$56, therefore, the total cost of implementation will be \$29,440. This gives a simple payback period for this E 28 of 1.1 years.

This facility has currently 100 tons of central air conditioning. 10 tons are high efficiency units and 90 tons are low efficiency units. There are three 30-ton and four 15-ton low efficiency units with an SEER of 10, they are about 10 years old. We analyzed the energy and cost savings for replacing the 30-ton units with units with a SEER of 10 and the 15-ton units with an SEER of 10. We did not recommend immediate replacement, but only when a unit fails. Since an air conditioning unit typically lasts 10 to 15 years, this recommendation will only be implemented if one or more of the units fails unexpectedly.

We analyzed the savings potential for a 30-ton unit and a 15-ton unit to show the company its options if one of the units fails. We did not include this savings in our overall savings chart because of its uncertainty. The savings and cost summary are shown in Table 1.

Size of AC Unit (tons):	30	15
SEER	10	10

Energy Savings	31,3	3).4
Cost Savings	00*	0*.
Cost premium	/)*	1)*
Utility Rate	31)	))*
Simple payback period	*.3/	*.,4

The office area of this facility is air conditioned (y nine rooftop units. Although the offices are only occupied from .A\*\* to 4A\*\* five days a week the air conditioning units operate 0/ hours a day. We recommended installing timers on the air conditioning units that would turn them on one hour before the start of normal working hours and turn them off when the offices closed. A manual override feature would allow air conditioning of offices when they were used at other times. Table #H shows the summary of energy and cost savings from installation of the timers.

3	)	..1	/k*/0	1.0
0	)	1*.*	0k3/)	1*4
/	1*	..1	11k/31	)1)
			11k.0/	.*3

The ceiling in the production area of the facility is /\* feet high. The air conditioning supply and return ducts are located in the ceiling. Because hot air rises the cold air will mix with hot air before it reaches the plant floor. We recommended lowering the supply and return ducts to 0\* feet to decrease the energy used by the air conditioners. Lowering the supply ducts means that colder air will reach the plant floor so less cold air will be needed. Lowering the return ducts means that cooler air will be returned to the air conditioning units thus improving their efficiency.

We analyzed the cooling load for the plant floor using the DOE\$0 program. The current energy consumption for air conditioning the plant floor is approximately )\*\*k. \*\* 5 6 7 <yr at a cost of a(out +0, k\*\*\*<yr. When the ducts were dropped to 0\* feet the simulation showed an energy consumption of approximately 3)\*k4\*\* 5 6 7 <yr with a cost of +0\*k3\*\*<yr. Thus the annual energy savings would be a(out 1)\*k\*\*\* 5 6 7 with an annual cost savings of +.k1\*\*. We estimated an implementation cost of +)k\*\*\* which gives a simple payback period of 1.1 years.

6 e also recommended several other measures that could save small amounts of energy at this facility. These included installing occupancy sensors to turn off lights in areas that were often unoccupied, replacing incandescent lamps in the e-it signs with GED units, and installing electronic variable voltage controls on the constant speed motors on the plastic regrinders which frequently stand idle. The dollar savings for the occupancy sensors and the motor controls were calculated using the off-peak cost of electricity (because neither of these measures guarantees a demand reduction during peak hours).

1. Occupancy sensors	1.1	10.	1.	000/0	*
0. GED e-it signs (GED 10. 1 hGED e-it signs)			1.		